


TANK OPENING:	4.85" X 1.62"	1. CORRECT CURRENT, B.I.L. RATING AND TANK OPENING (MAY 1/02)	 CROSSLINK TECHNOLOGY INC.	TITLE: 85-120	REVISION: 1
CONDUCTOR:	MACHINED COPPER			DESCRIPTION: SECONDARY BUSHING	
PLATING:	TIN			DIMMENSIONS: INCHES	SCALE: NOT TO SCALE
MATERIAL:	INDOOR EPOXY			DATE: SEPT. 15/92	SIGNED:
STD. COLOUR:	GREY			TOLERANCE: 0.000 = +/- 0.005 ; 0.00 = +/- 0.05 UNLESS OTHERWISE SPECIFIED	
CURRENT RATING:	2800 AMPS	IMPORTANT All information supplied by Crosslink Technology Inc. is furnished upon the express condition that the person receiving the product shall make his own assessments to determine its suitability for his particular purpose. No warranty is expressed or implied regarding such information or product; the results to be obtained from the use thereof, any product, as to its being merchantable or fit, for any particular purpose; the use of such information or product not infringing any patent.			
B.I.L.	30 k.V.				
VOLTAGE CLASS:	1.2 k.V.				
OTHER:					