


TANK OPENING:	N/A	1. NEW FORMAT 2. RECESS INSERTS 3. REVISE PLATING AND BIL	 CROSSLINK TECHNOLOGY INC
CONDUCTOR:	BRASS INSERTS		
PLATING:	N/A		
MATERIAL:	INDOOR EPOXY		
STD. COLOUR:	GREY		
CURRENT RATING:	N/A	IMPORTANT All information supplied by Crosslink Technology Inc. is furnished upon the express condition that the person receiving the product shall make his own assessments to determine its suitability for his particular purpose. No warranty is expressed or implied regarding such information or product; the results to be obtained from the use thereof, any product, as to its being merchantable or fit, for any particular purpose, the use of such information or product not infringing any patent.	TITLE: 90-107
B.I.L.	95 k.V.		REVISION: 3
VOLTAGE CLASS:	15 k.V.		DESCRIPTION: STANDOFF INSULATOR
OTHER:	6.5" CREEP		DIMENSIONS: INCHES
			SCALE: NOT TO SCALE
			DATE: FEB 16/95
			SIGNED:
			TOLERANCE: 0.000 = +/- 0.005 ; 0.00 = +/- 0.05 UNLESS OTHERWISE SPECIFIED